


## LP-TEST108B

### Measuring Principle

Lightning Protector Unit model LP-TEST 108 is to test the leakage current of MOV, break-over voltage and breakdown voltage of MOV, GDT, TVS & etc.



### Feature

- Small volume, convenient carrying.
- Quick response and accurate.
- LCD display, large font, clear and easy to identify.
- Battery and external power supply dual-use, easy to use.
- Intelligent testing with one-key, east to operate

### Application

- Tester of leakage current

### Main Technical Date

Model	LP-TEST 108B			
Test method	Automatic			
Power	DC 9V/ AA size batteries (4pcs )			
	Leakage current	Voltage	Resolution	Accuracy
Reference voltage	0.1 $\mu$ A accuracy	0-1000V	1V	3%
Break-over voltage	-	0-1000V	1V	3%

### Instruction



LKS West Instruments Sdn Bhd (834286-T)

No. 50-2, Jalan Sungai Rasau D32/D, Berjaya Park, Seksyen 32, 40460, Shah Alam, Selangor, Malaysia.

Tel: +603-5525 5038 Fax: +603-5525 5037 Email: [info.west@lkssb.com.my](mailto:info.west@lkssb.com.my) Webpage: [www.lkssb.com.my](http://www.lkssb.com.my)